

## SHOCK CHLORINATION

We recommend that you chlorinate your well according to the following table:

Well Size	Water Depth in Well	Add Bleach
2" Driven	for each 10 feet	1 oz.
6" Driven	for each 10 feet	¼ cup
24" Dug	for each 2 feet	¼ cup
36" Dug	for each 2 feet	½ cup

To chlorinate effectively, follow these steps:

1. Add chlorine bleach according to the table above.
2. Run each tap in the building until the odor of chlorine is noted.
3. Close taps, leave undisturbed at least four (4) hours, preferably longer. (overnight)
4. Use the water until the odor of chlorine is not noticeable. This can be done by continuously pumping or running the water. The chlorine left is harmless.

---

✓ Repeat test in 2 weeks

✓ Don't skimp on Clorox

✓ Don't use scented Clorox